

**ADDENDUM 001  
REQUEST FOR QUOTE  
Asphalt Pad for Neosho Fabric Building  
RFQ# D7-10-055**

Bidders/Offerors shall acknowledge receipt of Addendum 001 (ONE) by signing and mailto: [Christina.Stephens@modot.mo.gov](mailto:Christina.Stephens@modot.mo.gov) or including it with the original quote. The due date for receipt of quotes remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders/Offerors. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Chris Stephens Intermediate Procurement Agent
Bidder/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Chris Stephens</i> (Authorizing Signature)
Date Signed:	Date Signed: <b>4/7/2010</b>

**QUESTIONS/CLARIFICATIONS**

**Original Scope of work:**

"The Asphalt pad will be 6" thick and will be 46' by 80' dimensions. The Asphalt Contractor is required to use MoDOT Type 401 Bituminous and MoDOT Type BP-1 Surface Course Hot."

Asphalt Paving 6"  
Furnish and place 3" of MODT Type 401 Bituminous Base  
Furnish and place 3" of MoDOT Type 401 BP-1 Surface Course Hot.

**Revision to Scope of Work: Please bid according to this scope for both Line Item 001 and Line Item 002:**

"The Asphalt pad will be 8" thick and will be 46' by 80' dimensions. The Asphalt Contractor is required to use MoDOT Type 401 Bituminous and MoDOT Type BP-1 Surface Course Hot."

Asphalt Paving 8"  
Furnish and place 6" of MODT Type 401 Bituminous Base  
Furnish and place 2" of MoDOT Type 401 BP-1 Surface Course Hot.

Pads final layout will consist of:  
4" Type 5 Aggregate by MoDOT  
6" Bit Base  
2" Bit Pavement